



## **REQUEST FOR PROPOSAL (“RFP”) #5032ME**

**NEW TEMPORARY AIR STRUCTURE (TEMPORARY AIR SUPPORTED STRUCTURE)**

**AT CSU’S KRENZLER FIELD**

**RFP Issued Date: 1/2/2025**

**ADDENDUM #2**

**SPECIFICATIONS & REVISED PROPOSAL DUE DATE**

**Recommended Pre-Bid Meeting Date: 1/8/2025 @10:00am EST**

**Plant Services Building, 1802 E. 25<sup>th</sup> St, Rm 242, Cleveland, Ohio 44114**

**Questions due by: 1/9/2025 by 2:00pm EST via email with RFP #5032ME in the subject line**

**Extended Proposal Due Date /Time: 1/24/2025 by 2:00pm EST via email with RFP #5032ME in the subject line**

**Contact:**

**Michael Eames**

Purchasing Manager

[bids@csuohio.edu](mailto:bids@csuohio.edu)

**Proposals must be received by the due date/time specified above. Proposals received after the due date/time will be returned unopened to the supplier**

Please refer to the attached sheets for Instructions & Information. Proposals must be submitted on the form(s) provided and signed by an authorized representative in ink in the proper spaces. Vendors are cautioned to read this entire document carefully and to prepare and submit their Proposal providing all requested information in accordance with the terms and conditions set forth herein.

**REQUEST FOR PROPOSAL (“RFP”) #5032ME NEW TEMPORARY AIR STRUCTURE  
(TEMPORARY AIR SUPPORTED STRUCTURE) AT CSU’S KRENZLER FIELD**

**Addendum #2**

1. The Airlock Specifications calls for a 45 ft. in length Airlock. The correct specification should be for a 24 foot in length Airlock with 2 10x12 overhead doors.
2. Number of Exits calls for 10 and it should only be 7 exits.
3. Extend the submission day until Friday 1/24/25 to allow vendors to address 1 & 2 in this addendum.